

**California Regional Water Quality Control Board, Central Coast Region
SEWAGE OVERFLOW REPORT**

PRIVATE ~ **(Check if Applies)**

(Include all available details (use attachments as needed) - submit follow-up written reports as necessary)

Reporting Party	Santa Cruz County	Phone	(831) 477-3907
Discharger	SCCSD	Basin	Boulder Creek
Address	2750 Lode Street	City	Santa Cruz, CA 95062
Date of Overflow: 1/21/2010	Time Overflow Began: 1920	Time Overflow Stopped: 1955	
Responding Crew:	M Fryar, R Villamor		
Location/Address of Overflow Origin	Boulder Creek Treatment Plant		
Volume of Overflow 1750 gal	Path of flow: Into storm drain to creek		
Water body/Bodies Affected:	Boulder Creek		
Cause of Overflow:	Motor control failure		
Action Taken To Stop Overflow: Reset controls			
Time Cleanup Began: NA	Time Cleanup Completed: NA		
Discussion Of Cleanup: No cleanup due to heavy rains			
Were Public Health Warnings Posted, And If So, Where? NO	Number Of Overflows In Same Location In Last Three Years? 3		
Discussion Of Measures Taken To Prevent Overflows At This Time: None			
Agencies Notified: Name/Time/Dates:	Netcom: 1/21/10 2125 Christina	County Envir. Health: 1/21/10 2136 Message for J Ricker	
RWQCB: 1/21/10 2130 Message for M Higgins	County Board of Directors: Agenda date: _____	O.E.S.: 1/21/10 2140 Tim T 10-0554	
Fish & Game: 1/21/10 2130 Left message	Monterey Bay National Marine Sanctuary:	U.S.C.G. Monterey:	
U.S.C.G. Spill Response Ctr:	Other:		
SIGNATURE/TITLE GARY DUBINSKY ASSISTANT		DATE January 22, 2010	